2009 IBC and IFC amendments in compliance with SSB 5561 An Act relating to the installation of carbon monoxide alarms

**[F] 907.2.8 Group R-1**. Fire alarm systems, smoke alarms and carbon monoxide alarms shall be installed in Group R-1 occupancies as required in Sections 907.2.8.1 through 907.2.8.4.

**[F] 907.2.8.4. Carbon monoxide alarms**. For new construction, an approved carbon monoxide alarm shall be installed outside of each separate sleeping area in the immediate vicinity of the bedroom in sleeping units within which fuel fired appliances are installed, and in sleeping units that have attached garages.

**[F] 907.2.8.4.1 Existing sleeping units**. Existing sleeping units within which fuel fired appliances exist or that have attached garages shall be equipped with carbon monoxide alarms by January 1, 2013.

**[F] 907.2.8.4.2 Alarm requirements.** Single station carbon monoxide alarms shall be listed as complying with UL 2034 and shall be installed in accordance with this code and the manufacturer's installation instructions.

**[F] 907.2.9 Group R-2.** Fire alarm systems, smoke alarms and carbon monoxide alarms shall be installed in Group R-2 occupancies as required in Sections 907.2.9.1 through 907.2.9.3.

**[F] 907.2.9.3. Carbon monoxide alarms**. For new construction, an approved carbon monoxide alarm shall be installed outside of each separate sleeping area in the immediate vicinity of the bedroom in dwelling units within which fuel fired appliances are installed and in dwelling units that have attached garages.

**[F] 907.2.9.3.1 Existing dwelling units**. Existing dwelling units within which fuel fired appliances exist or that have attached garages shall be equipped with carbon monoxide alarms by January 1, 2013.

**[F] 907.2.8.4.2 Alarm requirements.** Single station carbon monoxide alarms shall be listed as complying with UL 2034 and shall be installed in accordance with this code and the manufacturer's installation instructions.

(Group R-4 not adopted, replace section)

**[F] 907.2.10 Group R-3**. Carbon monoxide alarms shall be installed in Group R-3 occupancies as required in Sections 907.2.10.1 through 907.2.10.3.

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

Formatted: Strikethrough

**[F] 907.2.10.1. Carbon monoxide alarms.** For new construction, an approved carbon monoxide alarm shall be installed outside of each separate sleeping area in the immediate vicinity of the bedroom in dwelling units within which fuel fired appliances are installed and in dwelling units that have attached garages.

Formatted: Strikethrough

**[F] 907.2.10.2 Existing dwelling units**. Existing dwelling units within which fuel fired appliances exist or that have attached garages shall be equipped with carbon monoxide alarms by January 1, 2013.

Formatted: Strikethrough

Exception: Owner-occupied Group R-3 residences legally occupied prior to July 1, 2010.

**[F] 907.2.10.3 Alarm requirements**. Single station carbon monoxide alarms shall be listed as complying with UL 2034 and shall be installed in accordance with this code and the manufacturer's installation instructions.

2009 IRC amendment in compliance with SSB 5561

**R315.1 Carbon monoxide alarms.** For new construction, an approved carbon monoxide alarm shall be installed outside of each separate sleeping area in the immediate vicinity of the bedroom in dwelling units within which fuel fired appliances are installed and in dwelling units that have attached garages.

Formatted: Strikethrough

**R315.2 Existing dwellings.** Existing dwellings within which fuel fired appliances exist or that have attached garages shall be equipped with carbon monoxide alarms by January 1, 2013.

Exception: Owner-occupied detached one-family dwellings legally occupied prior to July 1, 2010.

**R315.3 Alarm requirements**. Single station carbon monoxide alarms shall be listed as complying with UL 2034 and shall be installed in accordance with this code and the manufacturer's installation instructions.

Formatted: Strikethrough